

PRILOG 7

Gustina vazduha ρ (kg/m³)

| Temperatura vazduha (°C) | Relativna vlažnost vazduha (%) | | | | | |
|--------------------------------|----------------------------------|-------|-------|-------|-------|-------|
| | 0 | 20 | 40 | 60 | 80 | 100 |
| -10 | 1,342 | 1,342 | 1,341 | 1,340 | 1,340 | 1,339 |
| -5 | 1,317 | 1,316 | 1,315 | 1,314 | 1,313 | 1,312 |
| 0 | 1,293 | 1,291 | 1,290 | 1,288 | 1,287 | 1,285 |
| 5 | 1,270 | 1,268 | 1,265 | 1,263 | 1,261 | 1,259 |
| 10 | 1,247 | 1,244 | 1,241 | 1,238 | 1,235 | 1,232 |
| 15 | 1,226 | 1,222 | 1,217 | 1,213 | 1,209 | 1,205 |
| 20 | 1,205 | 1,199 | 1,194 | 1,188 | 1,183 | 1,177 |
| 25 | 1,185 | 1,177 | 1,170 | 1,162 | 1,155 | 1,148 |
| 30 | 1,165 | 1,155 | 1,145 | 1,136 | 1,126 | 1,116 |
| 35 | 1,146 | 1,133 | 1,121 | 1,108 | 1,095 | 1,082 |